



4/10/13

GSSN.R26410 - Fire-protective Curtains



**ONLINE CERTIFICATIONS DIRECTORY**

## **GSSN.R26410 Fire-protective Curtains**

[Page Bottom](#)

### **Fire-protective Curtains**

[See General Information for Fire-protective Curtains](#)

**BRADLEY LOMAS ELECTROLOK LTD**

R26410

CHURCH ST  
ECKINGTON  
SHEFFIELD, YORKSHIRE S21 4BH UNITED KINGDOM

**Fire-protective curtain**, Model SD60, 1 hr fire rating.

**Fire-protective curtain**, Model SD60G, 1 hr fire rating.

**Fire-protective curtain**, Model SD60GM, 1 hr fire rating.

**Fire-protective curtain**, Model SD240G, 2 hr fire rating when installed in gypsum and 3 hr fire rating when installed in masonry.

**Fire-protective curtain**, Model SD240GM, 2 hr fire rating when installed in gypsum and 3 hr fire rating when installed in masonry.

**Fire-protective curtain**, Model FC60, 1 hr fire rating.

**Fire-protective curtain**, Model FC60M, 1 hr fire rating.

**Fire-protective curtain**, Model FC240, 2 hr fire rating when installed in gypsum and 3 hr fire rating when installed in masonry.

**Fire-protective curtain**, Model FC240M, 2 hr fire rating when installed in gypsum and 3 hr fire rating when installed in masonry.

**The products below have been additionally investigated to ANSI/UL 1784**

**Fire-protective curtain**, Model SD60GS, 1 hr fire rating.

**Fire-protective curtain**, Model SD60GSM, 1 hr fire rating.

**Fire-protective curtain**, Model SD240GS, 2 hr fire rating when installed in gypsum and 3 hr fire rating when installed in masonry.

**Fire-protective curtain**, Model SD240GSM, 2 hr fire rating when installed in gypsum and 3 hr fire rating when installed in masonry.

**Fire-protective curtain**, Model FC60S, 1 hr fire rating.

**Fire-protective curtain**, Model FC60SM, 1 hr fire rating.

**Fire-protective curtain**, Model FC240S, 2 hr fire rating when installed in gypsum and 3 hr fire rating when installed in masonry.

**Fire-protective curtain**, Model FC240SM, 2 hr fire rating when installed in gypsum and 3 hr fire rating when installed in masonry.

[Last Updated](#) on 2012-06-08

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2013 UL LLC

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2013 UL LLC".